

Noise Assessments

Compressed Air Tools

Pre-Site

- Is this the quietest available equipment? Yes / No _____
- Is there an alternative quieter way to carry out the work? Yes / No _____
- Have alternative quieter methods of working been considered? Yes / No _____
- Can the work be carried out when there are reduced numbers on site? Yes / No _____
- Can the work be fabricated off site? Yes / No _____

On-Site

Where is the machine being used?	No Action	Have Hearing Protection Available	Ensure use of Hearing Protection	Signs	Min Attenuation Required dB
<input type="checkbox"/> Outdoors The level of noise is more than 85dB(A) but probably less than 90dB(A)	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	0
<input type="checkbox"/> Indoors The level of noise is likely to be more than 90dB(A) but probably less than 93dB(A)	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	3
<input type="checkbox"/> Confined Space The level of noise is likely to be more than 93dB(A) but probably less than 99dB(A) depending upon the size and nature of the confined space	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	10

Information

- Operatives have been informed of Risks, availability of PPE and any action required

Signed..... Position..... Date.....

Drills - Battery

Pre-Site

- Have non essential personnel been excluded from the area? Yes / No _____
- Can the work be carried out when there are reduced numbers on site? Yes / No _____

On-Site

Where is the machine being used?	No Action	Have Hearing Protection Available	Ensure use of Hearing Protection	Signs	Min Attenuation Required dB
<input type="checkbox"/> Outdoors The level of noise is probably less than 85dB(A)	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	0
<input type="checkbox"/> Indoors The level of noise is more than 85dB(A) but probably less than 90dB(A)	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	0
<input type="checkbox"/> Confined Space The level of noise is likely to be more than 90dB(A) but probably less than 96dB(A) depending upon the size and nature of the confined space	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	7

Information

- Operatives have been informed of Risks, availability of PPE and any action required

Signed..... Position..... Date.....